



## Certificate Of Analysis

**Date** 31-Jul-2015

**COA** 20150731-1

**Tank** B90

<b>D6751</b>		<b>Grade No. 2-B S15</b>	<b>Results</b>
Sulfur % mass (ppm), max	D5453	15	2.86
Cold soak filterability, seconds, max	D7501	360	107
Flash point (closed cup), °C, min	D93	93	165
Water and sediment, % volume, max	D2709	0.050	0
Water By Karl Fischer (ppm), max	D6304	500	97
Cloud point °C	D2500	Report	11.5
Visual Inspection Part 1, Haze Rating, max	D4176	2	1
Visual Inspection Part 2, n/a	D4176	Free of Particulate	Free of Particulate
Acid number, mg KOH/g, max	D974	0.50	0.35
Free glycerin, % mass, max	D6584	0.020	0.003
Monoglyceride, % mass, max	D6584	0.400	0.044
Total glycerin, % mass, max	D6584	0.240	0.028

**Authorized By**

**Andrew Meissner**